

**Drinking Water and Groundwater Protection Division**

One National Life Drive - Main 2 [phone] 802-828-1535  
Montpelier, VT 05620-3521 [fax] 802-828-1541

<http://dec.vermont.gov/water>

## WINHALL STRATTON F D 1 - VT0005305

### Consumer Confidence Report - 2018

This report is a snapshot of the quality of the water that we provided in 2018. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. This report is designed to inform you about the quality water and services we deliver to you every day. To learn more, please attend any of our regularly scheduled meetings which are held the last Thursday of each month at 4:00pm or the annual meeting held the second Saturday of January at 4:00pm at the Stratton Mountain Volunteer Fire House.

The person who can answer questions about this report is Margaret Dwyer, Water and Sewer Senior Manager at 802-297-9592 or [mdwyer@stratton.com](mailto:mdwyer@stratton.com).

### Water Source Information

**Your water comes from:**

Source Name	Source Water Type
WELL #44	Groundwater
WELL #45	Groundwater
WELL #46	Groundwater
WELL #47	Groundwater
WELL #48	Groundwater
WELL #49	Groundwater
WELL #17	Groundwater
WELL #18	Groundwater
WELL #30	Groundwater
WELL #31	Groundwater
WELL #33	Groundwater
WELL #50	Groundwater
WELL #51	Groundwater
WELL #35	Groundwater
WELL #38	Groundwater

The State of Vermont Water Supply Rule requires Public Community Water Systems to develop a Source Protection Plan. This plan delineates a source protection area for our system and identifies potential and actual sources of contamination. Please contact us if you are interested in reviewing the plan.

## Drinking Water Contaminants

The sources of drinking water (both tap water and bottled water) include surface water (streams, lakes) and ground water (wells, springs). As water travels over the land's surface or through the ground, it dissolves naturally-occurring minerals. It also picks up substances resulting from the presence of animals and human activity. Some "contaminants" may be harmful. Others, such as iron and sulfur, are not harmful. Public water systems treat water to remove contaminants, if any are present.

In order to ensure that your water is safe to drink, we test it regularly according to regulations established by the U.S. Environmental Protection Agency and the State of Vermont. These regulations limit the amount of various contaminants:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

**Pesticides and herbicides**, may come from a variety of sources such as storm water run-off, agriculture, and residential users.

**Radioactive contaminants**, which can be naturally occurring or the result of mining activity

**Organic contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the past year. It also includes the date and results of any contaminants that we detected within the past five years if tested less than once a year. The presence of these contaminants in the water does not necessarily show that the water poses a health risk.

**Terms and abbreviations** - In this table you may find terms you might not be familiar with. To help you better understand these terms we have provided the following definitions:

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Level 1 Assessment:** A level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment:** A Level 2 Assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Locational Running Annual Average (LRAA):** The average of sample analytical results for samples taken at a particular monitoring location during four consecutive calendar quarters.

**Maximum Contamination Level (MCL):** The "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

**Maximum Contamination Level Goal (MCLG):** The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLG's allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. Addition a disinfectant may help control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of disinfectants in controlling microbial contaminants.

**Nephelometric Turbidity Unit (NTU):** NTU is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Parts per billion (ppb) or Micrograms per liter (ug/l):** (one penny in ten million dollars)

**Parts per million (ppm) or Milligrams per liter (mg/l):** (one penny in ten thousand dollars)

**Picocuries per liter (pCi/L):** a measure of radioactivity in water

**Running Annual Average (RAA):** The average of 4 consecutive quarters (when on quarterly monitoring); values in table represent the highest RAA for the year.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**90th Percentile:** Ninety percent of the samples are below the action level. (Nine of ten sites sampled were at or below this level).

## Detected Contaminants WINHALL STRATTON F D 1

Disinfection Residual	RAA	RANGE	Unit	MRDL	MRDLG	Typical Source
Chlorine	0.617	0.010 - 1.300	mg/l	4	4	Water additive to control microbes

Chemical Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
Barium	01/17/2017	0.1	0 - 0.1	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride	01/03/2017	0.17	0 - 0.17	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Iron	01/17/2017	1.2	0 - 1.2	ppm	NA	NA	
Manganese	01/17/2017	48	0 - 48	ppb	NA	NA	Erosion of natural deposits. Vermont Department of Health has established a Health Advisory of 300 ppb. Manganese equal to or greater than 50 ppb can lead to unacceptable taste or staining of fixtures.
Nitrate	03/05/2018	0.3	0.2 - 0.3	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection ByProducts	Collection Year	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
Total Trihalomethanes	2018	25	25 - 25	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Collection Year	90th Percentile	Range	Unit	AL*	Sites Over AL	Typical Source
Copper	2016	0.56	0 - 1	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead	2016	4	0 - 60	ppb	15	1	Corrosion of household plumbing systems; Erosion of natural deposits

\*The lead and copper AL (Action Level) exceedance is based on the 90th percentile concentration, not the highest detected result.

## Health Information Regarding Drinking Water

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from EPA's Safe Drinking Water Hotline (1-800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. WINHALL STRATTON F D 1 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Uncorrected Significant Deficiencies

The system is required to inform the public of any significant deficiencies identified during a sanitary survey conducted by the Drinking Water and Groundwater Protection Division that have not yet been corrected. For more information please refer to the schedule for compliance in the system's Operating Permit.

Date Identified	Significant Deficiencies	Facility
07/29/2015	Test Equipment Unavailable/Inadequate or Inadequate Testing Reagent	
07/29/2015	Inadequate Chemical Application Facilities	SUNBOWL T.P. ( 35, 38, 40'S, 50, 51)
06/12/2018	Operation and Maintenance (O&M) Manual Needed	

**Public Notice - Permit to Operate Issued:** The Water System is required to notify all users of the following compliance schedule contained in the Permit to Operate issued by the State of Vermont Agency of Natural Resources:

1. The Water System must satisfy all conditions of permit to construct E-1334, submit as-built record drawings to the Division by **June 1, 2008**.
2. The Water System must update their Operation and Maintenance Manual to include all new portions of the Water System constructed since the last version and submit the revised manual to the Division for review and approval by **September 1, 2008**.
- 3.

The Winhall-Stratton Fire District has spent a significant amount of time and money to install the continuous chlorine monitoring and flow paced pumps for the chlorine disinfection systems. The systems are all being linked to the existing SCADA systems so that they monitoring results are transmitted to the plant for real time reporting and monitoring. Completion of the installation will meet the State determined deadlines outlined in the newly issued Permit to Operate issued in April 2019.

The engineer is in the process of updating the Operation and Maintenance Manuals.

The Winhall-Stratton Fire District is committed to providing safe, reliable drinking water to all of the users of the system. We strive to provide uninterrupted service and will notify all users in advance for scheduled maintenance. Unfortunately, we do sometimes experience emergencies which require us to shut off flow to certain parts of the system. We will do our best to keep those interruptions as short as possible and appreciate your understanding and patience. We also strive to keep costs as low as possible and that includes eliminating wasted water and leaks. If you have a toilet or faucet that is leaking, we ask that you get it repaired as soon as possible as even the smallest leaks can waste hundreds of gallons of water in a very short amount of time.