

Michigan’s new regulations limit seven PFAS chemicals in drinking water and we are currently required to test all 4 distribution points of our water system one time during 10/1/20 -12/31/20 and then quarterly.

Prior to the new regulation, our testing requirement was one distribution site sample quarterly which is listed in the East 3, Q1, Q2 and Q3 columns.

The Average column is an average of each quarter. If the average exceeds the MCL we would be in violation. At this time we are not in violation. All zeros mean the tested chemical was not detected in our water system.

If you have any questions or concerns regarding PFAS, the test or results, please contact Theresa at 231.773.0843 or visit [www.michigan.gov/pfasresponse](http://www.michigan.gov/pfasresponse)

<b>East 3</b>		PFAS quarterly results					
Name	Q4	Q3	Q2	Q1	Average	MCL	
PFNA	0	0	0	0	0	6	
PFOA	3	2	4	3	3	8	
PFOS	3	3	3	2	2.75	16	
PFHxS	0	0	0	0	0	51	
Gen X	0	0	0	0	0	370	
PFBS	0	0	2	2	1	420	
PFHxA	0	0	0	0	0	400,000	
<b>South 1</b>							
Name	Q4	Q3	Q2	Q1	Average	MCL	
PFNA	0				0	6	
PFOA	3				3	8	
PFOS	3				3	16	
PFHxS	0				0	51	
Gen X	0				0	370	
PFBS	0				0	420	
PFHxA	0				0	400,000	

<b>South 2</b>							
Name	Q4	Q3	Q2	Q1	Average	MCL	
PFNA	0				0	6	
PFOA	4				4	8	
PFOS	3				3	16	
PFHxS	0				0	51	
Gen X	0				0	370	
PFBS	3				3	420	
PFHxA	0				0	400,000	
<b>North</b>							
Name	Q4	Q3	Q2	Q1	Average	MCL	
PFNA	0				0	6	
PFOA	0				0	8	
PFOS	0				0	16	
PFHxS	0				0	51	
Gen X	0				0	370	
PFBS	0				0	420	
PFHxA	0				0	400,000	

0 = Non Detect, MCL = Maximum Contaminant Level